



3,800 LITRE TANK

SCALE 1:20

NOTES:

1. TANK TO BE MANUFACTURED AND TESTED IN ACCORDANCE WITH AS/NZS 1546.1:1998 ON-SITE DOMESTIC WASTEWATER TREATMENT UNITS PART 1 : SEPTIC TANKS.
2. CONCRETE STRENGTH $F'c = 40MPa$ SLUMP = 100mm MAXIMUM AGGREGATE SIZE = 10mm.
3. CONCRETE TO BE VIBRATED TO ENSURE THE MOULD IS FILLED WITH WELL COMPACTED CONCRETE.
4. TANKS TO BE REINFORCED WITH FIBRE STEEL - OR EQUIVALENT, MIXED AT A RATE OF 50 KILOGRAMS PER CUBIC METRE OF CONCRETE.
5. LIFTING HOOKS TO BE REID SWIFT LIFTS 4-2.5 TONNE, ANCHORS TO BE CAST INTO THE BASE OF THE TANK.
3-1.3 TONNE ANCHORS TO BE CAST INTO THE TANK LIDS.



Phone: 1800 006 176

JOB NUMBER.		K. D. HANSFORD Pty. Ltd. <small>ACN 058 040 292</small> CONSULTING ENGINEERS CIVIL / STRUCTURAL <small>LEMKO PL. PENRITH P.O. BOX 1351 PENRITH 2751 PHONE (02) 4721 7576</small>	DATE DEC '08	TITLE 3,800 LITRE CONCRETE TANK	PROJECT RAINWATER REUSE	AMENDMENTS A	
			DESIGN KDH			DRAWN MDH	SCALE 1:20
			CERTIFIED DATE				SHEET 2 OF 21 SHEETS